

ITEM B

LIQUID CHLORINE

SPECIFICATIONS AND BIDDING INFORMATION

BIDS CLOSE 3:00PM DECEMBER 2, 2025

1. Items A (Hydrofluosilicic Acid), B (Liquid Chlorine) and C (Phosphate Inhibitor) must be bid together and the bid will be based on the grand total of approximately 37,400 pounds of Hydrofluosilicic Acid, 18,000 pounds of Liquid Chlorine, and 3,600 gallons of Phosphate Inhibitor. Bids for only one or two of Items A, B and C will not be considered. Bid envelopes should be marked "Bid Opening – Chemical Bids" so that they are not opened in error.
2. Chemical Bids shall cover the City Water Department's requirements of Hydrofluosilicic Acid, Liquid Chlorine, and Phosphate Inhibitor for the period beginning January 1, 2026, and ending December 31, 2026.
3. Liquid Chlorine shall be in 150 pound cylinders.
4. Price bid shall be per CWT, delivered f.o.b. to the City Water Plants at various locations throughout the City. The price shall include the freight costs for return of the empty cylinders or containers.
5. Chlorine is to be used by the Water Plants as a health guard precaution; therefore, chlorine furnished must be pure and meet with the requirements of the State of Minnesota Department of Health.
6. Chlorine cylinders and valves shall meet all safety standards, with the City having the right to change suppliers should the lack of maintenance of cylinders be deemed hazardous to safety of employees.
7. Successful bidder shall deliver the Chlorine cylinders independently after the City shows the driver the locations for the first delivery.
8. Successful bidder will maintain existing chemicals feed equipment for cost of parts only.